ABB STOTZ-KONTAKT GmbH, Postfach 10 16 80, 69006 Heidelberg
ABB Oy
Valimopolku 4
00380 Helsinki
Finland

Person in charge Angela Masembe
E-mail angela.masembe@de.abb.com
Our Reference 2CDN073672P1001

Date 27.11.2023

CONFIRMATION OF COMPLIANCE

We hereby confirm that CM-UFD.M33 (1SVR560730R3402) and CM-UFD.M33M (1SVR560731R3702) ABB grid feeding monitoring relays are network and system protection devices for three-phase parallel connection to the public grid. Both relays comply with the following standard:

EN 50549-1:2019
Requirements for generating plants to be connected in parallel with distribution networks - Part 1: Connection to a LV distribution network - Generating plants up to and including Type B

4.9 Interface Protection

with the following conditions of acceptability:
- reset time of devices may need to be evaluated in the end-use application, refer to datasheet.
- inhibition of frequency protection functions may need to be evaluated in the end-use application, refer to datasheet.

This statement of confirmation is valid for the present design according to the standards as written in the data sheets. Technical data and diagrams for CM-UFD.M33 (1SVR560730R3402) and CM-UFD.M33M (1SVR560731R3702) are publicly available in document no. 2CDC112210D0201 Rev. H (08/2023) and document no. 2CDC112 271D201 Rev. G (07/2023) respectively.

This confirmation is valid for the present design according to the standards as written in the data sheets.

This certificate is maximum valid until 27.11.2026.

Also a change of the design could make this certificate invalid.

All former confirmations or certificates issued by us before date of this confirmation/certificate are to be considered null and void and have no further validity.

With best regards,

ABB STOTZ-KONTAKT GmbH

i.V. Christian Trattnig
DE-ELSP - Quality Manager

i.V. Juergen S. Schmidt
R&D Team Manager

This certificate has been released via a personalized electronic workflow and is valid without signature.

ABB Stotz-Kontakt GmbH
Besuchsanschrift:
Eppelheimer Straße 82
69123 Heidelberg
Telefon: +49 6221 701 0
E-Mail: info.stotz@de.abb.com

www.abb.de/stotz-kontakt

Sitz der Gesellschaft:
Heidelberg
Registergericht: Mannheim
Handelsregister: HRB 336474
Ust-IdNr.: DE811176562

Vorsitzender des Aufsichtsrates:
Markus Ochsner
Geschäftsführung:
Adalbert Neumann (Vorsitzender),
Esther Hoffmann

Bankverbindung:
Deutsche Bank AG, Frankfurt
IBAN (€):
DE15120700700240207021
IBAN (Fremdwährung):
DE03500700100850697400
BIC: DEUTDEFFXXX