



EVPU[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0880

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Esmi Impresia Manual Call Point FFS06741004

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**Schneider Electric Buildings AB,
Mobilvägen 8, 223 62 Lund, Sweden**

and produced in the manufacturing plant

**Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-11:2001, EN 54-11:2001/A1:2005,
EN 54-17:2005, EN 54-17:2005/AC:2007**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on March 14th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, March 14th, 2024

054909

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 2 FCO 425-13 Rev.2




Michal Mišiak
Head of CB NB No. 1293

Annex to Certificate No. 1293 - CPR – 0880 from March 14th, 2024

General information

Esmi Impresia Manual Call Point FFS06741004 is designed for installing in addressable fire alarm systems with Esmi ELC loop controller supporting Schneider Electric communication protocol. The call point has a built-in isolator module which when used allows continuous operation of the loop in case of short circuit and without need of using additional isolator modules. The address setting is done by the panel, QR code or handheld addressing device.

Technical specifications

Operating voltage:	15÷32VDC
Type (according to EN 54-11,17):	A
Type of frangible element	Resettable (flexible)
Indication "Fire alarm"	red LED
Material (plastic), color	ABS, red
Dimensions:	90x90x57mm
Weight:	≤ 175g
Supported communication protocol	Esmi ELC

Essential characteristics	Harmonised technical specification		Performance
	EN 54-11:2001 EN 54-11/A1:2005	EN 54-17:2005 EN 54-17/AC:2007	
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 5.2, 5.3	cl. 5.2	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.9	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.12	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.13	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	cl. 5.3, 5.13	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0774	Original certificate issued	April 1 st , 2021
2	1293-CPR-0880	New company name and location New location of place of production	March 14 th , 2024

Nová Dubnica, March 14th, 2024




Michal Mišiak
Head of CB NB No. 1293