



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0886

In compliance with the *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Esmi Impresia 4 Inputs/0 Outputs Module FFS06741010

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**Schneider Electric Buildings AB,
Mobilvägen 8, 223 62 Lund, Sweden**

and produced in the manufacturing plant

**Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 54-18:2005, EN 54-18:2005/AC:2007,
EN 54-17:2005, EN 54-17:2005/AC:2007**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on March 14th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, March 14th, 2024




Michal Mišiak
Head of CB NB No. 1293

054915

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 2 FCO 425-13 Rev.2

Annex to Certificate No. 1293 - CPR – 0886 from March 14th, 2024

General information

Esmi Impresia 4 Inputs/0 Outputs Module FFS06741010 is an addressable module, that monitors four analogue input signals and is designed for installing in addressable fire alarm systems with Esmi ELC loop controller supporting Schneider Electric communication protocol. The module has a built-in isolator module which when used allows continuous operation of the loop in case of module's failure and without need of using additional isolator modules. The module is mounted in a separate plastic box suitable for wall mounting and with IP55 protection. The address setting is done by the panel, QR code or handheld addressing device.

Technical specifications


Operating voltage	16 ÷ 32VDC
Degree of protection:	IP55
Dimensions	176x126x57mm
Weight	~ 320g
Material (plastic), color	PS, grey
Supported communication protocol	Esmi ELC

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0780	Original certificate issued	April 1 st , 2021
2	1293-CPR-0886	New company name and location New location of place of production	March 14 th , 2024

Nová Dubnica, March 14th, 2024



Michal Mišiak
Head of CB NB No. 1293