

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Automatic reclosing devices (ARDs) associated to RCCBs

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
F-38050 Grenoble Cedex 9
France

Name and address of the manufacturer

GEWISS S.p.A.
Via A. Volta, 1
24069 Cenate Sotto (BG)
Italy

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2GEWISS PORTUGAL Indústria del Material Eléctrico, Unipessoal, Lda
Zona Industrial 2a fase - Bustelo
4560-043 Penafiel
Portugal

Ratings and principal characteristics

Un 230 V; 50 Hz; Rd 16 kΩ or 5 kΩ; Rd0 8 kΩ or 2,5 kΩ
(see also pages 7 and 10 of Test Report PB20-0057114-01-00 or Additional Sheet)

Trademark (if any)



Schneider Electric

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

series RED and REDs
(see also page 10 of Test Report PB20-0057114-01-00 or Additional Sheet)

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 63024:2017

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

PB20-0057114-01-00 and from PB20-0057114-01-01 to PB20-0057114-01-03

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.
Via Quintiliano 43, IT-20138 Milano, Italy

Description of the automatic reclosing devices series RED and REDs

		Ratings of the ARD part			Ratings of the associated RCCB		
Series	Type reference	Condition after fault	R _d	R _{d0}	Type	I _n	I _{Δn}
RED	A9CR2225	Blocked	16 kΩ	8 kΩ	A	25 A	30 mA
	A9CR1225						
	A9CR2240					40 A	
	A9CR1240					63 A	
	A9CR1263						
REDs	A9CR4225	Tripped	5 kΩ	2,5 kΩ		25 A	300 mA
	A9CR4240					40 A	
	A9CR4263					63 A	
	A9CR5225			25 A			
	A9CR5240			40 A			
	A9CR5263			63 A			