



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2600080

Socket-outlet

Type designation: NU-037--, NU-057--, NU-066--, NU-067--A, NU-067--AS, NU-076--

Certificate holder: Schneider Electric Industries SAS
35 rue Joseph Monier
FR 92500 Rueil-Malmaison
France

The product complies with the standard(s): IEC 60884-1:2022
SS 428 08 34:2024
NEK 502:2016 +A1

Date of expiry: 28 January, 2031

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: 
Anneli Averland Johansson **Date:** 28 January, 2026

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

APPENDIX:

Reference No. SE-S-2600080

Technical Data:

Type designation	NU-037--
Rated voltage (V)	250 VAC
Rated current (A)	16A
IP-Class	20
Standard sheet	III
Trademark	
Test Report	2510305STO-001
Product information	Single socket-outlet, screw terminals, with shutters. With cover NVE6545702 to be assembled with accessories

Type designation	NU-057--
Rated voltage (V)	250 VAC
Rated current (A)	16A
IP-Class	20
Standard sheet	III
Trademark	
Test Report	2510305STO-001
Product information	Single socket-outlet, screw-less terminals, with shutters. With cover NVE6545702 to be assembled with accessories.

Type designation	NU-066--
Rated voltage (V)	250 VAC
Rated current (A)	16A
IP-Class	20
Standard sheet	III
Trademark	
Test Report	2510305STO-001
Product information	Double socket-outlet, screw-less terminals, with shutters. With cover NVE6925502 to be assembled with accessories.

Type designation	NU-067--A
Rated voltage (V)	250 VAC
Rated current (A)	16A
IP-Class	20
Standard sheet	III
Trademark	
Test Report	2510305STO-001
Product information	Double socket-outlet, screw and insulating piercing terminals, with shutters. With cover NVE6925502 to be assembled with accessories.

APPENDIX:

Reference No. SE-S-2600080

<i>Type designation</i>	NU-067--AS
<i>Rated voltage (V)</i>	250 VAC
<i>Rated current (A)</i>	16A
<i>IP-Class</i>	20
<i>Standard sheet</i>	III
<i>Trademark</i>	
<i>Test Report</i>	2510305STO-001
<i>Product information</i>	Double socket-outlet with signal lamp, screw and insulating piercing terminals, with shutters. With cover NVE6925502 to be assembled with accessories.

<i>Type designation</i>	NU-076--
<i>Rated voltage (V)</i>	250 VAC
<i>Rated current (A)</i>	16A
<i>IP-Class</i>	20
<i>Standard sheet</i>	III
<i>Trademark</i>	
<i>Test Report</i>	2510305STO-001
<i>Product information</i>	Triple socket-outlet screw-less terminals, with shutters. With cover MFR3955102 to be assembled with accessories.

Accessory Cover-plates:

NU2002--, NU2004--, NU2006--, NU2008--, NU2010--, NU2102--, NU2103--, NU2104--,
NU4002--, NU4004--, NU4006--, NU4008--, NU4110--, NU4114--, NU4116--, NU4118--,
NU6002--, NU6004--, NU6004V--, NU6006--, NU6008—

Accessory Supporting frames:

NU7002, NU7002P, NU7004PC, NU7006C, NU7008C,
NU7103, NU7103P, NU7104, NU7892, NVE6944902

Accessories intended for floor, desk, service pole, service post and other similar non flush wall installations.

Type NU-067--A, NU-067--AS are not applicable for Norway.

Accessory Cover-Plates and Accessory Supporting Frames are not applicable for Norway.

APPENDIX:

Reference No. SE-S-2600080

Manufacturing Sites: Schneider Electric Espana S.A.
Ctra. Pamplona-Logroño, s/n
31100 Puente la Reina (Navarra)
SPAIN



Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: 
Anneli Averland Johansson **Date:** 28 January, 2026