

CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



STATEMENT OF TEST RESULTS


STR/2640/IMQ

Product	Automatic reclosing devices (ARDs) associated to automatic test device and assembled with residual current circuit-breaker (RCCB)
Tested by request of	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France
Manufactured at (name and place)	GEWISS PORTUGAL Indústria del Material Eléctrico, Unipessoal, Lda Zona Industrial 2a fase, 4560 – 043 PENAFIEL – Portugal
Preliminary visit carried out by	—
Rating and principal characteristics	3P+N; 230 V; 50 Hz; 40 or 63 A; R _d = 5 or 16 kΩ; R _{d0} = 2,5 or 8 kΩ (see Additional Sheet and pages 6 and 9 of Test Report No. PB21-0061856-01-00)
Trade mark (if any)	
Model/Type Ref.	REDtest series (see Additional Sheet and page 9 of Test Report No. PB21-0061856-01-00)
Additional information (if necessary)	Testing location/procedure: CTF Stage 2
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)	
• EN 63024:2018 • IMQ Technical Specification CPT-054 5th Ed. 2021	
as shown in the test reports (reference No.)	PB21-0061856-01-00 and from PB21-0061856-01-01 to PB21-0061856-01-04

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

IMQ S.p.A.



DocuSign

Milano, 2021-12-16

Signature of the authorized person

Name and function of the authorized person

Mauro Casari

B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager

Tel.: (+39) 02-50731
Fax.: (+39) 02-50991500
e-mail: info@imq.it

**STATEMENT OF TEST RESULTS**

Additional Sheet to STR/2640/IMQ

Description of ARDs (assembled with RCCB) REDtest series

Type reference	Ratings of the ARD module				Ratings of the associated RCCB				
	Condition after fault	U_e	R_d	R_{d0}	Number of poles	U_e	I_n	Type	$I_{\Delta n}$
A9CR6440	Tripped	230 V	16 k Ω	8 k Ω	3P+N	400 V	40 A	A SI (*)	0,03 A
A9CR6463	Tripped	230 V	16 k Ω	8 k Ω	3P+N	400 V	63 A	A SI (*)	0,03 A
A9CR7440	Tripped	230 V	5 k Ω	2,5 k Ω	3P+N	400 V	40 A	A SI (*)	0,3 A
A9CR7463	Tripped	230 V	5 k Ω	2,5 k Ω	3P+N	400 V	63 A	A SI (*)	0,3 A

(*) – “A SI”-type RCCBs are “A”-type RCCBs with an intentional short-time delay.