

Essentia Optical Smoke Detector EDE-222-I

Instruction Sheet
R10078GB2



Schneider Electric
www.se.com/buildings

R10078GB2
October 2023

© 2018-2023 – Schneider Electric. All Rights Reserved. This information is only to be used as guidance. Subject to changes and errors.

Contents

Safety Information	4
Related Information	4
1 Essentia Optical Smoke Detector EDE-222-I	4
1.1 Feature highlights.....	4
1.2 Application.....	4
1.2.1 Essentia optical smoke detector response modes	5
1.2.2 Dimensions	5

Safety Information

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction, installation, and operation of electrical equipment and has received safety training to recognize and avoid the hazards involved.

Related Information

For technical specifications, please refer to the Product Datasheet for FFS06720301 on se.com.

1 **Essentia Optical Smoke Detector EDE-222-I**

The addressable Essentia Optical Smoke Detector EDE-222-I (FFS06720301) with isolator uses new optical sensing technology to detect smoke particles entering the chamber and aims to reduce the possibility false alarms whilst increasing the reliability of detection of a real fire.

1.1 **Feature highlights**

- Detector utilizes digital communications
- Compatible with Intellia systems.
- Mechanically compatible with existing bases.
- Detector has tri-colored LED status indication and remote indicator output.
- Comprehensively tested to exceed EN 54-7 standard.
- Detector can be locked to the base.
- Has a built-in drift compensation.

1.2 **Application**

Fire detectors should always be installed in accordance with all local and national laws and codes of practice.

Optical smoke detectors are recommended for general use, particularly where there is a risk of slow burning fires or where the development of smoke could become the major hazard.

1.2.1 Essentia optical smoke detector response modes

Mode	Response Value		Minimum Time to Alarm
	%/m*	dB/m**	Seconds
1	1.4	0.10	5
2	1.4	0.10	30
3	2.1	0.14	5
4	2.1	0.14	30
5	2.4	0.16	5

* Tested in grey smoke

** Tested in oil mist to EN 54-7 standard

1.2.2 Dimensions

