

ETA-Danmark A/S
Kollegievej 6
DK-2920 Charlottenlund
Tel. +45 72 24 59 00
Fax +45 72 24 59 04
Internet www.etadanmark.dk



Authorised and notified according to Article 10 of the Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of Member States relating to construction products

MEMBER OF EOTA

European Technical Approval ETA-12/0027

Trade name:

SCHÖNOX AB Watertight covering kit

Holder of approval:

AKZO NOBEL Building Adhesives
SCHÖNOX GmbH
Alfred-Nobel-Strasse 6
D-48720 Rosendahl
Telephone + 49 2547 910-0
Telefax +49 2547 910-101
Internet www.schoenox.de

Generic type and use of construction product:

Watertight covering kit for wet room floors and walls based on flexible sheets

Valid from:
to:

2012-09-07
2017-09-07

Manufacturing plant:

AKZO NOBEL Building Adhesives
SCHÖNOX GmbH
Alfred-Nobel-Strasse 6
D-48720 Rosendahl

This European Technical Approval contains:

14 pages including 2 annex which form an integral part of the document



European Organisation for Technical Approvals

Europæisk Organisation for Tekniske Godkendelser

I LEGAL BASIS AND GENERAL CONDITIONS

1 This European Technical Approval is issued by ETA-Danmark A/S in accordance with:

- Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of Member States relating to construction products¹⁾, as amended by Council Directive 93/68/EEC of 22 July 1993²⁾.
- Bekendtgørelse 559 af 27-06-1994 (afløser bekendtgørelse 480 af 25-06-1991) om ikrafttræden af EF direktiv af 21. december 1988 om indbyrdes tilnærmelse af medlemsstaternes love og administrative bestemmelser om byggevarer.
- Common Procedural Rules for Requesting, Preparing and the Granting of European Technical Approvals set out in the Annex to Commission Decision 94/23/EC³⁾.
- EOTA Guideline for European Technical Approvals, ETAG No 022 *Watertight covering kits for wet room floors and/or walls*, Part 2: Kits based on flexible sheets, Edition November 2010

2 ETA-Danmark A/S is authorized to check whether the provisions of this European Technical Approval are met. For this purpose a notified body shall execute twice a year surveillance, judgement and assessment of factory production control. Checking will take place in the manufacturing plant. Nevertheless, the responsibility for the conformity of the products to the European Technical Approval and for their fitness for the intended use remains with the holder of the European Technical Approval.

3 This European Technical Approval is not to be transferred to manufacturers or agents of manufacturers other than those indicated on page 1, or manufacturing plants other than those indicated on page 1 of this European Technical Approval.

4 This European Technical Approval may be withdrawn by ETA-Danmark A/S pursuant to Article 5(1) of Council Directive 89/106/EEC.

- 1) Official Journal of the European Communities N° L40, 11 Feb 1989, p 12.
- 2) Official Journal of the European Communities N° L220, 30 Aug 1993, p 1.
- 3) Official Journal of the European Communities N° L 17, 20 Jan 1994, p 34.

5 Reproduction of this European Technical Approval including transmission by electronic means shall be in full. However, partial reproduction can be made with the written consent of ETA-Danmark A/S. In this case partial reproduction has to be designated as such. Texts and drawings of advertising brochures shall not contradict or misuse the European Technical Approval.

6 This European Technical Approval is issued by ETA-Danmark A/S in English. This version corresponds fully to the version circulated within EOTA. Translations into other languages have to be designated as such.

II SPECIAL CONDITIONS OF THE EUROPEAN TECHNICAL APPROVAL

1 Definition of product and intended use

General

SCHÖNOX AB is a flexible sheet membrane kit which serves as a watertight covering for wet room floors and walls beneath a wearing surface.

The kit consists of the following components (Annex 2 describes the alternative trade names for the components of the kit):

Primer

SCHÖNOX KH, which is a single component synthetic resin dispersion primer and SCHÖNOX KH Fix or a layer of SHP, which is a single component solvent free acrylate dispersion primer for various substrates. These primers are not intended to have a significant additional function in limiting the water vapour permeability of the kit.

Alternatively, for applications where the primer is intended to have a significant additional function in limiting the water vapour permeability of the kit SCHÖNOX SPR Primer can be used, which is a single component polyvinylidene chloride dispersion.

Membrane

SCHÖNOX AB is a 3-ply waterproof membrane consisting of two outer layers of polypropylene non-wovens and an inner layer of polyethylene. The thickness of the membrane is 0,50 mm and the weight is 270 g/m².

Reinforcement

The reinforcement is SCHÖNOX ST Sealing Tape or SCHÖNOX BT Butyl tape, which is used in connection between the floor and the wall, in corners and around penetrations. SCHÖNOX ST is embedded in layers of SCHÖNOX iFIX or SCHÖNOX 1K DS membrane and readymade fitting pieces are used in inside and outside corners. Reinforcement around pipe penetrations in floors and wall is established with SCHÖNOX ST D collars, which are available in various sizes depending on the pipe diameter. For gullies the SCHÖNOX ST FC, - ST BR or – ST-BC is used depending on the working principle and installation principle of the gully.

Adhesives

Adhesives covered by this ETA is: SCHÖNOX CFK PLUS, SCHÖNOX SFK, SCHÖNOX PFK, SCHÖNOX PFK RAPID, SCHÖNOX PFK WHITE, SCHÖNOX PFK PLUS, SCHÖNOX SK, SCHÖNOX SEK, SCHÖNOX SLK PLUS, SCHÖNOX Q9W, SCHÖNOX Q9, SCHÖNOX TT S8, SCHÖNOX TT S8 RAPID, SCHÖNOX TT PLUS, SCHÖNOX KR and SCHÖNOX CF

The kit is constructed as follows:

- a layer of 40 - 75 g/m² SCHÖNOX KH (depending on substrate) or 150 g/m² SCHÖNOX KH Fix (depending on substrate) and a layer SCHÖNOX SHP or 2 layers SCHÖNOX SPR Primer (150 g/m² + 100 g/m²).
- reinforcement of in- and out going corners in walls, over joints or cracks in the substrate, around pipe penetrations, floor gullies and along the connection between floor and wall with is SCHÖNOX ST Sealing Tape, which is embedded in a layer of SCHÖNOX HA membrane or with the self adhesive synthetic rubber reinforcement SCHÖNOX BT Butyl tape. Reinforcement around pipe penetrations in floors and wall is established with SCHÖNOX ST D collars, which are available in various sizes depending on the pipe diameter. For gullies the SCHÖNOX ST FC, - ST BR or – ST BC is used depending on the working principle and installation principle of the gully
- SCHÖNOX AB adhered to the substrate with approx. 0,5 kg/m² SCHÖNOX iFIX adhesive or SCHÖNOX HA or Schönox 1K DS membrane or SCHÖNOX tile adhesive
- a layer of ceramic tiles adhered to the kit with cement based tile adhesive.

Intended use

The intended use of the covering kit is:

1. watertight covering for use beneath a wearing surface, normally in the form of tiles, on substrates of wood based panels, gypsum boards, fibre cement boards, cement bonded boards, watertight boards made from a polystyrene core with a cement based glass fibre reinforced covering and concrete, i.e. moisture sensitive substrates, which are flexible and with jointing and susceptible to cracking

The kit can be used with the following types of floor gullies:

Circular and rectangular gullies made from stainless steel or plastic type PE, with flange for adhesion of the membrane or with clamping ring or with collar

2. Indoor applications, where the liquid applied kit is not exposed to temperatures (i.e. temperature of structure) below 5 °C and above 40 °C, in the following uses:

- Floor and wall surfaces with only occasional direct exposure to water, e.g. at a good distance from shower or bathtub.
- Floors and walls in shower areas or around bathtubs used for a few showers daily, e.g. in ordinary dwellings, multi-family houses and hotels
- Floor and wall surfaces with exposure to water more frequent or of longer duration than normally anticipated in dwellings, e.g. public wet rooms, schools and sport facilities.

Assumed working life

The assumed intended working life of the kit for the intended use is 25 years, provided that they are subject to appropriate installation, use and maintenance.

An “assumed intended working life” means that it is expected that, when this working life has elapsed, the real working life may be, in normal use conditions, considerably longer without major degradation affecting the essential requirements.

The indications given as to the working life of the boards cannot be interpreted as a guarantee given by SCHÖNOX GmbH or ETA-Danmark A/S.

2 Characteristics of product and assessment

ETAG para.	Characteristic	Assessment of characteristic
	2.1 Mechanical resistance and stability	Not relevant.
	2.2 Safety in case of fire	
2.4.1	Reaction to fire	Euroclass E
	2.3 Hygiene, health and the environment	
2.4.2	Dangerous substances	No dangerous materials *)
2.4.3.	Vapour permeability	The vapour permeability of the SCHÖNOX AB membrane with primer when tested at 23°C and RH 93 → 50 %: The s_d value of the membrane at RH 93 → 50 % is 96,4 m
2.4.4	Moisture resistance	
	Water tightness	Watertight according to EN 1928 method B
	Crack bridging ability	Assessment category 3: Crack width 1,5 mm
	Bond strength	SCHÖNOX AB and the each of the tile adhesives mentioned in section 1 of this ETA on a concrete substrate all comply with Assessment category 2: Bond strength > 0,3 MPa SCHÖNOX AB membrane and the each of the tile adhesives mentioned in section 1 of this ETA on substrates**) of calcium silicate boards, gypsum boards, fibre cement boards, cement based boards and watertight boards made from a polystyrene core with a cement based glass fibre reinforced covering comply with Assessment category 2: Bond strength > 0,3 Mpa
	Scratching resistance	No performance determined
	Joint bridging ability	SCHÖNOX AB and 0,5 kg/m ² SCHÖNOX PFK tile adhesive and Shönox SFK Nordic respectively Assesment category 2: Watertight
	Water tightness around penetrations	SCHÖNOX KH Primer, SCHÖNOX AB and 0,5 kg/m ² SCHÖNOX iFIX adhesive or SCHÖNOX HA or SCHÖNOX 1K DS membrane or SCHÖNOX tile adhesive and SCHÖNOX reinforcement (see II.1)***) comply with Assesment category 2: Watertight

ETAG para.	Characteristic	Assessment of characteristic
	Joint strength	No performance determined
	Flexibility	No performance determined
2.4.5	2.4 Safety in use Slipperiness	Not relevant
	2.5 Protection against noise	Not relevant
	2.6 Energy economy and heat retention	Not relevant
	2.7 Related aspects of durability and serviceability	
2.4.7.1	Dimensional stability	The declared values are: Longitudinal direction (MD): $\bar{\alpha}_{AL} = -0,5 \%$ Transverse direction (CMD): $\bar{\alpha}_{AL} = -1,3 \%$
2.4.7.2	Resistance to temperature	Pass. The tensile strength and the strain at maximum force of a sample of SCHÖNOX AB were determined before and after heat exposure. The deviation before and after ageing was considerably lower than 20% and therefore no further investigations are required to assess that the resistance to temperature.
2.4.7.3	Resistance to water	SCHÖNOX AB with the all thhe listed tile adhesives on a concrete substrate all comply with Assessment category 2: Bond strength > 0,3 Mpa
2.4.7.4	Resistance to alkalinity	Pass. The tensile strength and the strain at maximum force of a sample of SCHÖNOX AB were determined before and after alkaline exposure. The deviation before and after ageing was considerably lower than 20% and therefore no further investigations are required to assess that the resistance to alkalinity. Assessment Category 2: 50 °C for 16 weeks

ETAG para.	Characteristic	Assessment of characteristic
2.4.7.6	Resistance to mechanical wear	Not relevant
2.4.7.1	Cleanability	Not relevant
2.4.7.2	Repairability	Repairable
2.4.7.3	Thickness	The thickness of the SCHÖNOX AB is determined to be 0,50 mm
2.4.7.4	Applicability	Applicable

*) In accordance with <http://europa.eu.int/-/comm/enterprise/construction/internal/dangsub/dangmain.htm> In addition to the specific clauses relating to dangerous substances contained in this European Technical Approval, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the EU Construction Products Directive, these requirements need also to be complied with, when and where they apply.

**) The assessment of the fitness for use of the kit on the generic description of the boards is based on test on the following specified substrates in addition to concrete according to EN 1323; SCHÖNOX cement based screeds and SCHÖNOX cement based floor leveling compounds, calcium sulfate based screeds, Sakret render cement based, Weber chalk cement render, Knauf gypsum plasterboard (MP 75L), Illbruck polystyrene dry board, cellular concrete blocks, Fermacell gypsum fibre boards, Wedi Building board and old ceramic tile surfaces

***) In accordance with the provisions of ETAG 022 part 1 – Annex A, the kit has been tested with three types of floor gullies; two circular gullies, one made from stainless steel with a flange for floors with a membrane and one in PP plastic with a clamping ring type KL/150, and on rectangular gully made from stainless steel with a flange for installation in wood based floors structures

3 Attestation of Conformity and CE marking

3.1 Attestation of Conformity system

According to the decision 2003/655/EC of the European Commission system 2+ for the procedure of the attestation of conformity (Annex III, clause 2(ii) first possibility of Directive 89/106/EC) applies to the watertight covering kit.

There is no declared fire performance, and hence the Decision 2003/655/EC of the European Commission with regard to reaction to fire is not relevant.

The system of attestation of conformity is 2+ is defined as follows.

- a) Tasks for the manufacturer:
- (1) Factory production control,
 - (2) Initial type testing of the product,
 - (3) testing of samples taken at the factory in accordance with a prescribed test plan
- b) Tasks for the notified body:
- (1) Initial inspection of the factory and the factory production control,
 - (2) Continuous surveillance

3.2 Responsibilities

3.2.1 Tasks of the manufacturer

3.2.1.1 Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall insure that the product is in conformity with this ETA.

The factory production control shall be in accordance with the appropriate part of the control plan¹ which is confidential part of the MTD. The control plan is laid down in the context of the factory production control system operated by the manufacturer and deposited with ETA-Danmark.

The manufacturer may only use initial materials according to the MTD. He shall inspect or control the

initial materials on acceptance according to the control plan.

The factory production control follows the identifying properties of the components and the example of the control plan as given in ETAG 022 part 1.

The results of the factory production control shall be recorded and evaluated in accordance with the provisions of the control plan.

The records shall include at least the following information:

- name of the product and of the initial materials,
- type of inspection or control,
- date of manufacture of the product, batch N° if needed, and date of inspection or control of the product or of the initial materials,
- result of inspections or controls and, as far as applicable, comparison with the requirements,
- signature of the person responsible for the factory production control.

The records shall be kept for at least five years. On request they shall be presented to ETA-Danmark.

Details concerning extent, type and frequency of the tests or inspections to be performed within the scope of the factory production control shall correspond to the control plan which is part of the MTD to this ETA.

3.2.1.2 Initial type-testing of the product

The initial type-testing refers to the product properties stated in the appropriate part of the control plan to this ETA. It follows the example of the control plan as given in ETAG 022 part 1.

If the verifications underlying this ETA have been furnished on samples from the current production, these will replace the initial type-testing.

Otherwise the necessary initial type-testing shall be carried out according to the provisions of the control plan and observance of the required property values shall be ascertained by the manufacturer.

After changing the production process or starting the production in another manufacturing plant the initial type-testing shall be repeated.

3.2.1.3 Other tasks for the manufacturer

The manufacturer shall, on the basis of a contract, involve a body/bodies which is/are notified for the tasks referred to in section 3.1(b) in the field of the product in order to undertake the actions laid down in section 3.2.2. For this purpose, the control plan referred to in section 3.2.2 shall be handed over by the manufacturer to the notified body/bodies involved.

The manufacturer shall make a declaration of

¹ The "control plan" is a confidential part of the MTD to this ETA and deposited with ETA-Danmark. It contains the required information on the factory production control and on the initial type-testing. As far as this is relevant to the tasks of the notified body involved in the procedure of attestation of conformity the control plan will be handed over to the notified body. See section 3.2.2.

conformity, stating that the product is in conformity with the provisions of this ETA and shall mark the product with the CE mark according to clause 3.3.

3.2.2. Tasks of notified bodies

3.2.2.1 Initial inspection of the factory and of factory production control

The appropriate part of the control plan states the information on the properties which have to be controlled by the notified body involved for initial inspection of factory and factory production control. The notified body has to control the devices and equipments and the documentation of the factory production control of the manufacturer when starting the production.

The notified body shall retain the essential points of its actions referred to above and state the results obtained and conclusions drawn in a written report.

The notified certification body involved by the manufacturer shall issue an EC certificate of conformity of the factory production control stating the conformity with the provisions of this ETA.

After changing the production process or starting the production in another manufacturing plant the initial inspection of factory and factory production control shall be repeated. The notified body shall issue a new EC certificate of conformity of the factory control stating the conformity with the provisions of this ETA.

3.2.2.3 Continuous surveillance, assessment and approval of factory production control.

The appropriate part of the control plan states the information on the product properties which have to be checked by the notified body involved. The frequency of this tasks should be twice a year.

The notified body shall retain the essential points of its actions referred to above and state the results obtained and conclusions drawn in a written report.

In cases where the provisions of this ETA and its control plan are no longer fulfilled the certification body involved shall withdraw the certification of conformity and inform ETA-Danmark without delay.

3.3 CE marking

The CE marking² shall be affixed on the packaging of the kit of the watertight membrane "SCHÖNOX AB" or its accompanying documents.

The letters "CE" shall be followed by the identification number of the notified body, and be accompanied by the following additional information:

- name and address or identifying mark of the manufacturer,
- last two digits of the year in which the CE marking was affixed,
- number of the EC certificate for the factory production control,
- number of the European technical approval,
- number of the European technical guideline.

The components shall be specified as belonging to the composite waterproofing kit "SCHÖNOX AB".

² Notes on the CE marking are stated in Guidance Paper D "CE marking under the Construction Products Directive", Brussels, 01 August 2002

4 Assumptions under which the fitness of the product for the intended use was favourably assessed

4.1 Manufacturing

All materials shall be manufactured by SCHÖNOX GmbH or by subcontractors under the responsibility of SCHÖNOX GmbH.

The European Technical Approval is issued for the product on the basis of agreed data/information, deposited with ETA-Danmark, which identifies the product that has been assessed and judged. Changes to the product or production process, which could result in this deposited data/information being incorrect, should be notified to ETA-Danmark before the changes are introduced. ETA-Danmark will decide whether or not such changes affect the ETA and consequently the validity of the CE marking on the basis of the ETA and if so whether further assessment or alterations to the ETA, shall be necessary.

4.2 Design and dimensioning

The fitness for the respective use of the watertight membrane results from the characteristic values and categories.

The supplementing statements of the manufacturer stated in the MTD for design and application of the watertight system for creating a watertight covering under wearing surface for floors and walls in indoor wet areas shall be considered.

4.3 Installation

The fitness for use of the watertight membrane can be assumed only, if the installation is carried out according to the installation instructions stated in the MTD by the manufacturer, in particular taking account of the following points:

- installation by appropriately trained personnel,
- installation of only those components which are specified components of the kit,
- installation with the required tools and adjuvant, precautions during installation,
- inspecting the substrate surface for cleanliness and correct treatment,
- inspections during installation and of the finished watertight membrane and documentation of the results.

The information as to the handling of waste products shall be observed.

4.4 Manufacturers responsibility

It is the manufacturer's responsibility to make sure that all those who utilize the kit will be appropriately informed about the specific conditions according to sections 1, 2, 4, and 5 including the annexes to this ETA and the not confidential parts of the MTD deposited to this ETA.

5 Indications to the manufacturer

5.1 Packaging, transport and storage

Information on:

- Packaging
- transport and
- storage

are given in the MTD.

5.2 Use, maintenance and repair


Information on:

- Use
- maintenance
- repair

are given in the MTD.



Thomas Bruun
Manager, ETA-Danmark



Description:

1. Substrates with SCHÖNOX Primer
2. SCHÖNOX ST BT directly on substrates
3. SCHÖNOX ST + SCHÖNOX ST IC or SCHÖNOX ST EA with SCHÖNOX iFIX or SCHÖNOX 1K DS
4. SCHÖNOX ST BC directly on substrate overlapping with SCHÖNOX iFIX or SCHÖNOX 1K DS
5. SCHÖNOX ST FC (with SCHÖNOX ST BR) with SCHÖNOX iFIX or SCHÖNOX 1K DS on substrate, overlapping also with SCHÖNOX iFIX or SCHÖNOX 1K DS
6. SCHÖNOX iFIX or SCHÖNOX 1K DS for overlapping from SCHÖNOX AB
7. SCHÖNOX AB and SCHÖNOX iFIX or SCHÖNOX tile adhesive for fixing from SCHÖNOX AB on substrate
8. SCHÖNOX ST D for pipe with SCHÖNOX iFIX or SCHÖNOX 1K DS, protection from the overlapping with SCHÖNOX iFIX, SCHÖNOX 1K DS or SCHÖNOX HA
9. SCHÖNOX tile adhesive for wall and floor tiles

SCHÖNOX AB watertight covering kit	Annex 1
Principle build-up of the kit	of European Technical Approval ETA-12/0027

European Market	Germany	Nordic	France
Brand label	SCHÖNOX	SCHÖNOX	CEGEGOL
Foil	SCHÖNOX AB	AB / WSF	CEGEDRY
Accessoires	SCHÖNOX ST		CEGEDRY BJ
		WetStop SH	
		WetStop KL	
	SCHÖNOX ST IC or EA	SCHÖNOX ST IC or ST EA	CEGEDRY AR or AS
		WetStop PC / PC-E	
	SCHÖNOX ST D	SCHÖNOX ST D	CEGEDRY MT
		WetStop MP	
	SCHÖNOX ST BC	SCHÖNOX ST BC	
	WetStop MG / MG-L		
	SCHÖNOX ST FC (+ ST BR)		CEGEDRY MS 425 (+PS 97)
Primer	SCHÖNOX KH	SCHÖNOX KH	
			CEGEPRIM E
	SCHÖNOX KH FIX	SCHÖNOX KH FIX	CEGEPRIM AN
	SCHÖNOX SHP	SCHÖNOX SHP	
			CEGEPRIM RN
Products for fixing from the foil on the substrate	SCHÖNOX iFIX	SCHÖNOX iFIX	iFIX
		SCHÖNOX WSA	
		SCHÖNOX HA	
	all recommended SCHÖNOX tile adhesives		recommended C2 CEGECOL tile adhesives
Products for overlapping	SCHÖNOX iFIX	SCHÖNOX iFIX	iFIX
	SCHÖNOX 1K DS	SCHÖNOX 1K DS	AQUAPROOF 1K DS
		WetStop 2-comp.	
Tile adhesive	SCHÖNOX SK PREMIUM	SCHÖNOX SEK	
	SCHÖNOX SK	SCHÖNOX SK	
	SCHÖNOX Q9-W	SCHÖNOX Q9-W	
	SCHÖNOX Q9	SCHÖNOX Q9	
	SCHÖNOX SLK PLUS	SCHÖNOX SLK PLUS	
	SCHÖNOX PFK	SCHÖNOX PFK	
	SCHÖNOX PFK PLUS	SCHÖNOX PFK PLUS	CARROFLEX ASP
	SCHÖNOX PFK WHITE	SCHÖNOX PFK WHITE	

SCHÖNOX PFK RAPID	SCHÖNOX PFK RAPID	CARROFLEX SPR
SCHÖNOX SFK		CARROFLEX SFG
	SCHÖNOX SFK 3631	
SCHÖNOX CFK PLUS	SCHÖNOX CFK PLUS	
SCHÖNOX TT S8	SCHÖNOX TT S8	CARROFLUID MAX
SCHÖNOX TT S8 RAPID	SCHÖNOX TT S8 RAPID	
SCHÖNOX TT PLUS	SCHÖNOX TT PLUS	
SCHÖNOX KR		
SCHÖNOX CF	SCHÖNOX CF	
		CARROSOUPLE HP
		CARROFLUID N2
		CARROFLEX HDE (gris / white)

SCHÖNOX AB watertight covering kit	Annex 2 of European Technical Approval ETA-12/0027
Principle build-up of the kit	