

QUINTIN CERTIFICATIONS
825 route de Romans
38160 SAINT ANTOINE
L'ABBAYE - France
Tél. +33.(0)7 66 29 39 28
info@quintincertifications.fr
www.quintincertifications.com

CERTIFICATE OF CONFORMITY N°RQC2021-072/A

1. APPLICANT

Applicant: Mr Christophe TIMMERMANS
Manufacturer: FALLPROTEC SA - ZARO 2-4 Rue Gustave Loosé - L-8346 Grass - Luxembourg

2. EQUIPMENT

Type of equipment: **Anchor system type D1, D2, D3, D4, D5, D6 and D7 BS8610:2017***
Trademark: **FALLPROTEC SA**
Reference: **SAFEACCESS**

3. DESCRIPTION

anchor system type D in aluminum with the following parameter of use:

- Use only in overhead position with 1 trolley NAV2 or NAV7 per user
- The junction element reference MHS075 must be installed at maximum 0.5 m from the screws
- Must be used only at the horizontal, no angle allowed
- Maximum cantilever: 0.5 m
- No turn allowed
- Fixed end stop reference MHS017
- Retractable end stop reference MHS033



(full description and results in the conformity report n°RQC2021-072-1).

4. TECHNICAL REFERENTIAL

The anchor system D1, D2, D3, D4, D5, D6 and D7 has been evaluated according to the relevant requirement of the British standard BS8610:2017* "Personal fall protection equipment – Anchor systems - specification".

5. CONDITION OF USE


The anchor system D1, D2, D3, D4, D5, D6 and D7 is designed for a maximum system rating SR_{max} at 300 kg, it can be used by 3 people with a maximum rated mass RM_{max} at 100 kg except for D6, only 2 people allowed.

It is intended to be used with maximum span of 6m and fixed by 2 screws DIN603 M12 in stainless steel A2 reference MHS 614 spaced 110 mm maximum on steel plate anchor with a minimum thickness of 8 mm.

6. CONCLUSION

The anchor system D1, D2, D3, D4, D5, D6 and D7, reference **SAFEACCESS**, presented by **FALLPROTEC SA** and described in the conformity report RQC2021-072-1, conforms to the requirements of British standard BS8610:2017*.

19/04/2022
The head of QUINTIN CERTIFICATIONS
Guillaume QUINTIN



QUINTIN
Validation électronique

Only the tests described in the harmonised standard marked with asterisk are performed under COFRAC accreditation, the instruction for use and marking are not covered by COFRAC accreditation. QUINTIN CERTIFICATIONS does not allow partial reproduction of this document and reproduction of the COFRAC logo. The full reproduction of this document is the only one allowed.

Cette attestation d'une page ne constitue pas le justificatif prévu par le code de la consommation (article L-115-27) par lequel un organisme distinct du fabricant atteste à des fins commerciales qu'un produit est conforme à des caractéristiques dans un référentiel déposé auprès de l'autorité administrative

QUINTIN CERTIFICATIONS – 825 route de Romans – 38160 SAINT ANTOINE L'ABBAYE – France TEL +33 (0) 7 66 29 39 28 – Email : info@quintincertifications.fr
SARL au capital de 10 000 € - SREN 848 919 676 - TVA intracommunautaire FR81848919676

QC-151-V3- Attestation de conformité Cofrac GB/RQC2021-072 A_FALLPROTEC.docx